



NOTES:

1. KEEP TRENCH BOTTOM COMPACTED WITH UNIFORM GRADE. A BELL JOINT SHALL BE REQUIRED AT EACH JOINT FOR PROPER SUPPORT. NO TEMPORARY SUPPORTS, I.E. BLOCKS, WILL BE ALLOWED TO SUPPORT PIPE. TRENCH BOTTOM SHALL BE TO GRADE PRIOR TO PIPE INSTALLATION.
2. TRENCH SHALL BE PLATED UNTIL FINAL LIFT OF MATERIAL IS PLACED.



TRENCH RESTORATION FOR UNPAVED AREAS

STANDARD PLAN: ST - 040	CITY ENGINEER APPROVAL:
DATE: FEB.2007	Longview: C.B.
	Kelso: S.Z.