

SANITARY SEWERS

ALL SANITARY SEWERS ARE TO BE D-3034 PVC WITH 12 GAUGE SOFT DRAWN (GREEN) TRACER WIRE AS INDICATED ON THE PLANS, AND SHALL BE TESTED CLEANED, AND TV'd IN ACCORDANCE WITH THE CITY OF LONGVIEW STANDARD SPECIFICATIONS.

ALL SANITARY SEWER LATERALS ARE TO BE A MINIMUM 6" PVC WITH A MINIMUM SLOPE OF 2% EXCEPT AS INDICATED ON THE PLANS. LATERALS SHALL HAVE 36" COVER OVER TOP OF PIPE AT RIGHT-OF-WAY LINE, OR SHALL REQUIRE DUCTILE IRON PIPE & APPROVAL FROM THE CITY OF LONGVIEW.

CLEANING BY USE OF HIGH PRESSURE NOZZLE REQUIRED PRIOR TO TESTING.

TELEVISION INSPECTION OF ALL SANITARY SEWER LINES IS REQUIRED.

PULLING MANDRELL IN ALL SANITARY SEWER LINES IS REQUIRED.

VACUUM TESTING ALL NEW SANITARY SEWER MANHOLES IS REQUIRED.

TRACE WIRE TEST TO PROVE CONTINUITY IS REQUIRED.

ALL SANITARY SEWER PIPE WHICH CROSS WATER PIPES SHALL BE DUCTILE IRON PIPE 20' SECTION CENTERED OVER WATER PIPE.

AS BUILT DRAWINGS & TV REPORTS SHALL BE SUBMITTED & APPROVED PRIOR TO ACCEPTANCE.

ALL BACKFILL SHALL BE $\frac{3}{8}$ " MINUS (CSTC).

FOUNDATION MATERIAL & GEO GRID SHALL BE INSTALLED AS DIRECTED BY THE CITY OF LONGVIEW & TO THE DEPTH AS DIRECTED.

ALL PAVEMENT PATCHES SHALL BE 2" PLUS EXISTING IN DEPTH OR AS DIRECTED BY THE CITY OF LONGVIEW.

ALL PAVEMENT SHALL BE FULL DEPTH SAWCUT & REPLACED PER THE LIMITS AS MARKED BY THE CITY OF LONGVIEW AFTER CONSTRUCTION.

THE EXISTING SANITARY SEWER SYSTEM SHALL STAY ISOLATED FROM THE NEW SYSTEM VIA MECHANICAL PLUG UNTIL THE NEW SYSTEM IS CLEANED, TESTED, T.V.'d, & APPROVED FOR USE.



SANITARY SEWER GENERAL NOTES

STANDARD PLAN:
SS - 000

DATE: **FEB. 2007**

CITY ENGINEER APPROVAL:

Longview: **C.B.**

Kelso: **S.Z.**