

Weekly Schedule Update for Water Treatment Plant
Submitted July 26, 2010

Accomplishments for the week of July 19, 2010 – July 25, 2010

- Routine Plant Operation and Maintenance
- Weekend sewer station duties.
- Receive caustic delivery.
- Work on review of usace sediment and flood protection documents.
- Finish monthly water quality.
- Continue filter inspections #2 also remove wafer check and clean air scour piping along with associated cla-vlave maintenance.
- Ca tank batch.
- Assist as requested to repair and locate telem line at Finney.
- Order lab and turbidity meter maintenance supplies.

Projected Plan for the week of July 26, 2010 – August 1, 2010

- Routine Plant Operation and Maintenance.
- Weekend sewer station duties.
- Work on pricing for water quality.
- Cl well on Friday or dive project if paperwork done.
- Repair siding and paint at well as needed.
- Continue filter inspections and associated cla-vlave maintenance and wafer check removal to flush air scour system.
- New construction samples as requested.
- Work on review of usace sediment and flood protection documents.
- Work on RFP for systems integrator as directed.
- Clean caustic containment area, order pipe, fittings and caustic glue to replace leaking fittings.
- Small works roster for dive project is out, work with w/s to coordinate upcoming project.
- Continue testing chemical changes extending filter runs.